

Laboratory Report

Analysis Requested by:	Agua Solutions
Sample collected by / Date	Agua Solutions
Date received	10- June-08
Sample ID	Elloy Treatment Plant

TEST	STANDARDS *	RESULTS	REFERENCE
Total Coliforms (MPN/100 mL)	FIO*	Positive 210 NMP/100mL	NLab-MT-PTO-001
Fecal Coliforms (MPN/100 mL)	Negative (<2 NMP/100mL)	Negative (<2 NMP/100mL)	NLab-MT-PTO-001

Comments:

*For Information Only

Interpretation of results:

Potable Water according to **Microbiological Standards**.

Treatment of the water system is recommended.

- **Results are only valid for the sample analyzed.**

General Observations:

*Values of the "Reglamento para la Calidad del Agua Potable", decree N° 32327-S from Health Ministry, La Gaceta No. 84 .

Method: Standard Methods for the examination of water and waste water. 20 th edition.

Dr. Dietrich Faersón
Regente
1675
MQC7 code

LABORATORIO NANDA

Liberia (506)8395-8839

laboratorionanda@yahoo.com